



Latest Chemical Results - PWS ID: 00458 ---- RIVERBEND-RIVERBANK COMMUNITY

Sample ID	Sample Date	Receive Date	Chemical	Source ID	Results	Current MCL	UOM
010505402-V	04/14/20	05/22/20	1,1,1-TRICHLOROETHANE	EP-A	ND	0.2	MG/L
010505402-V	04/14/20	05/22/20	1,1,2-TRICHLOROETHANE	EP-A	ND	0.005	MG/L
010505402-V	04/14/20	05/22/20	1,1-DICHLOROETHYLENE	EP-A	ND	0.007	MG/L
010505402-V	04/14/20	05/22/20	1,2,4-TRICHLOROBENZENE	EP-A	ND	0.07	MG/L
010505401-S	04/14/20	05/22/20	1,2-DIBROMO-3-CHLOROPROPANE	EP-A	ND	0.0002	MG/L
010505402-V	04/14/20	05/22/20	1,2-DICHLOROETHANE	EP-A	ND	0.005	MG/L
010505402-V	04/14/20	05/22/20	1,2-DICHLOROPROPANE	EP-A	ND	0.005	MG/L
010505401-S	04/14/20	05/22/20	2,4,5-TP	EP-A	ND	0.05	MG/L
010505401-S	04/14/20	05/22/20	2,4-D	EP-A	ND	0.07	MG/L
010505403-I	04/14/20	05/22/20	ANTIMONY, TOTAL	EP-A	ND	0.006	MG/L
010505403-I	04/14/20	05/22/20	ARSENIC	EP-A	ND	0.01	MG/L
010505401-S	04/14/20	05/22/20	ATRAZINE	EP-A	ND	0.003	MG/L
10505403	04/14/20	05/22/20	BARIUM	EP-A	0.0346	2	MG/L
010505402-V	04/14/20	05/22/20	BENZENE	EP-A	ND	0.005	MG/L
010505401-S	04/14/20	05/22/20	BENZO(A)PYRENE	EP-A	ND	0.0002	MG/L
10505403	04/14/20	05/22/20	BERYLLIUM, TOTAL	EP-A	ND	0.004	MG/L
010505401-S	04/14/20	05/22/20	BHC-GAMMA	EP-A	ND	0.0002	MG/L
010505403-I	04/14/20	05/22/20	CADMIUM	EP-A	ND	0.005	MG/L
010505401-S	04/14/20	05/22/20	CARBOFURAN	EP-A	ND	0.04	MG/L
010505402-V	04/14/20	05/22/20	CARBON TETRACHLORIDE	EP-A	ND	0.005	MG/L
010505401-S	04/14/20	05/22/20	CHLORDANE	EP-A	ND	0.002	MG/L
010505402-V	04/14/20	05/22/20	CHLOROBENZENE	EP-A	ND	0.1	MG/L
10505403	04/14/20	05/22/20	CHROMIUM	EP-A	ND	0.1	MG/L
010505402-V	04/14/20	05/22/20	CIS-1,2-DICHLOROETHYLENE	EP-A	ND	0.07	MG/L
010505403-I	04/14/20	05/22/20	CYANIDE	EP-A	ND	0.2	MG/L
010505401-S	04/14/20	05/22/20	DALAPON	EP-A	ND	0.2	MG/L
010505401-S	04/14/20	05/22/20	DI(2-ETHYLHEXYL) ADIPATE	EP-A	ND	0.4	MG/L
010505401-S	04/14/20	05/22/20	DI(2-ETHYLHEXYL) PHTHALATE	EP-A	ND	0.006	MG/L
010505402-V	04/14/20	05/22/20	DICHLOROMETHANE	EP-A	ND	0.005	MG/L
010505401-S	04/14/20	05/22/20	DINOSEB	EP-A	ND	0.007	MG/L
010505401-S	04/14/20	05/22/20	DIQUAT	EP-A	ND	0.02	MG/L
010505401-S	04/14/20	05/22/20	ENDOTHALL	EP-A	ND	0.1	MG/L
010505401-S	04/14/20	05/22/20	ENDRIN	EP-A	ND	0.002	MG/L
010505402-V	04/14/20	05/22/20	ETHYLBENZENE	EP-A	ND	0.7	MG/L
010505401-S	04/14/20	05/22/20	ETHYLENE DIBROMIDE	EP-A	ND	0.00005	MG/L
010505403-I	04/14/20	05/22/20	FLUORIDE	EP-A	0.16	4	MG/L
010505401-S	04/14/20	05/22/20	GLYPHOSATE	EP-A	ND	0.7	MG/L
010505404-R	04/14/20	05/22/20	GROSS ALPHA, EXCL. RADON & U	EP-A	ND	15	PCI/L
010505401-S	04/14/20	05/22/20	HEPTACHLOR	EP-A	ND	0.0004	MG/L
010505401-S	04/14/20	05/22/20	HEPTACHLOR EPOXIDE	EP-A	ND	0.0002	MG/L
010505401-S	04/14/20	05/22/20	HEXACHLOROBENZENE	EP-A	ND	0.001	MG/L
010505401-S	04/14/20	05/22/20	HEXACHLOROCYCLOPENTADIENE	EP-A	ND	0.05	MG/L

010505401-S	04/14/20	05/22/20	LASSO		EP-A	ND	0.002	MG/L
010505403-I	04/14/20	05/22/20	LEAD		EP-A	ND	0.015	MG/L
010505403-I	04/14/20	05/22/20	MERCURY		EP-A	ND	0.002	MG/L
010505401-S	04/14/20	05/22/20	METHOXYCHLOR		EP-A	ND	0.04	MG/L
10505403	04/14/20	05/22/20	NICKEL		EP-A	ND	0.1	MG/L
010505403-I	04/14/20	05/22/20	NITRATE (annual)		EP-A	ND	10	MG/L
010505403-I	04/14/20	05/22/20	NITRITE		EP-A	ND	1	MG/L
010505402-V	04/14/20	05/22/20	O-DICHLOROBENZENE		EP-A	ND	0.6	MG/L
010505401-S	04/14/20	05/22/20	OXAMYL		EP-A	ND	0.2	MG/L
010505402-V	04/14/20	05/22/20	P-DICHLOROBENZENE		EP-A	ND	0.075	MG/L
010505401-S	04/14/20	05/22/20	PENTACHLOROPHENOL		EP-A	ND	0.001	MG/L
010505401-S	04/14/20	05/22/20	PICLORAM		EP-A	ND	0.5	MG/L
010505403-I	04/14/20	05/22/20	SELENIUM		EP-A	ND	0.05	MG/L
010505401-S	04/14/20	05/22/20	SIMAZINE		EP-A	ND	0.004	MG/L
010505403-I	04/14/20	05/22/20	SODIUM		EP-A	21.1		MG/L
010505402-V	04/14/20	05/22/20	STYRENE		EP-A	ND	0.1	MG/L
010505402-V	04/14/20	05/22/20	TETRACHLOROETHYLENE		EP-A	ND	0.005	MG/L
10505403	04/14/20	05/22/20	THALLIUM, TOTAL		EP-A	ND	0.002	MG/L
010505402-V	04/14/20	05/22/20	TOLUENE		EP-A	ND	1	MG/L
019102401-D	07/09/20	07/21/20	TOTAL HALOACETIC ACIDS (HAA5)		DIST-A	ND	0.06	MG/L
010505401-S	04/14/20	05/22/20	TOTAL POLYCHLORINATED BIPHENYLS (PCB)		EP-A	ND	0.0005	MG/L
010505401-S	04/14/20	05/22/20	TOXAPHENE		EP-A	ND	0.003	MG/L
010505402-V	04/14/20	05/22/20	TRANS-1,2-DICHLOROETHYLENE		EP-A	ND	0.1	MG/L
010505402-V	04/14/20	05/22/20	TRICHLOROETHYLENE		EP-A	ND	0.005	MG/L
019102401-D	07/09/20	07/21/20	TTHM		DIST-A	0.0011	0.08	MG/L
010505402-V	04/14/20	05/22/20	VINYL CHLORIDE		EP-A	ND	0.002	MG/L
010505402-V	04/14/20	05/22/20	XYLENES, TOTAL		EP-A	ND	10	MG/L

15601601	06/04/20	06/23/20	COPPER	residence #1	DIST-A	ND	1.3	MG/L
15601601	06/04/20	06/23/20	LEAD	residence #1	DIST-A	ND	0.015	MG/L
15601602	06/04/20	06/23/20	COPPER	residence #2	DIST-A	0.081	1.3	MG/L
15601602	06/04/20	06/23/20	LEAD	residence #2	DIST-A	ND	0.015	MG/L
15601603	06/04/20	06/23/20	COPPER	residence #3	DIST-A	ND	1.3	MG/L
15601603	06/04/20	06/23/20	LEAD	residence #3	DIST-A	0.003	0.015	MG/L
15601604	06/04/20	06/23/20	COPPER	residence #4	DIST-A	ND	1.3	MG/L
15601604	06/04/20	06/23/20	LEAD	residence #4	DIST-A	0.004	0.015	MG/L
15601605	06/04/20	06/23/20	COPPER	residence #5	DIST-A	0.133	1.3	MG/L
15601605	06/04/20	06/23/20	LEAD	residence #5	DIST-A	ND	0.015	MG/L
15601606	06/04/20	06/23/20	COPPER	residence #6	DIST-A	0.163	1.3	MG/L
15601606	06/04/20	06/23/20	LEAD	residence #6	DIST-A	ND	0.015	MG/L
15601607	06/04/20	06/23/20	COPPER	residence #7	DIST-A	0.078	1.3	MG/L
15601607	06/04/20	06/23/20	LEAD	residence #7	DIST-A	0.007	0.015	MG/L
15601608	06/04/20	06/23/20	COPPER	residence #8	DIST-A	ND	1.3	MG/L
15601608	06/04/20	06/23/20	LEAD	residence #8	DIST-A	ND	0.015	MG/L

909401101-I	04/04/19	04/12/19	NITRATE (annual)	EP-A	ND	10	MG/L
804302601-I	02/13/18	02/23/18	NITRATE (annual)	EP-A	ND	10	MG/L
719900702-V	07/18/17	12/14/17	1,1,1-TRICHLOROETHANE	EP-A	ND	0.2	MG/L
719900702-V	07/18/17	12/14/17	1,1,2-TRICHLOROETHANE	EP-A	ND	0.005	MG/L
719900702-V	07/18/17	12/14/17	1,1-DICHLOROETHYLENE	EP-A	ND	0.007	MG/L
719900702-V	07/18/17	12/14/17	1,2,4-TRICHLOROBENZENE	EP-A	ND	0.07	MG/L
719900702-S	07/18/17	11/10/17	1,2-DIBROMO-3-CHLOROPROPANE	EP-A	ND	0.0002	MG/L
719900702-V	07/18/17	12/14/17	1,2-DICHLOROETHANE	EP-A	ND	0.005	MG/L
719900702-V	07/18/17	12/14/17	1,2-DICHLOROPROPANE	EP-A	ND	0.005	MG/L
719900702-S	07/18/17	11/10/17	2,4,5-TP	EP-A	ND	0.05	MG/L
719900702-S	07/18/17	11/10/17	2,4-D	EP-A	ND	0.07	MG/L
719900702-S	07/18/17	11/10/17	ATRAZINE	EP-A	ND	0.003	MG/L
719900702-V	07/18/17	12/14/17	BENZENE	EP-A	ND	0.005	MG/L
719900702-S	07/18/17	11/10/17	BENZO(A)PYRENE	EP-A	ND	0.0002	MG/L
719900702-S	07/18/17	11/10/17	BHC-GAMMA	EP-A	ND	0.0002	MG/L
719900702-S	07/18/17	11/10/17	CARBOFURAN	EP-A	ND	0.04	MG/L
719900702-V	07/18/17	12/14/17	CARBON TETRACHLORIDE	EP-A	ND	0.005	MG/L
719900702-S	07/18/17	11/10/17	CHLORDANE	EP-A	ND	0.002	MG/L
719900702-V	07/18/17	12/14/17	CHLOROBENZENE	EP-A	ND	0.1	MG/L
719900702-V	07/18/17	12/14/17	CIS-1,2-DICHLOROETHYLENE	EP-A	ND	0.07	MG/L
719900702-R	07/18/17	11/10/17	COMBINED RADIUM (-226 & -228)	EP-A	ND	5	PCI/L
719900702-R	07/18/17	11/10/17	COMBINED URANIUM	EP-A	ND	0.03	MG/L
719900702-S	07/18/17	11/10/17	DALAPON	EP-A	ND	0.2	MG/L
719900702-S	07/18/17	11/10/17	DI(2-ETHYLHEXYL) ADIPATE	EP-A	ND	0.4	MG/L
719900702-S	07/18/17	11/10/17	DI(2-ETHYLHEXYL) PHTHALATE	EP-A	ND	0.006	MG/L
719900702-V	07/18/17	12/14/17	DICHLOROMETHANE	EP-A	ND	0.005	MG/L
719900702-S	07/18/17	11/10/17	DINOSEB	EP-A	ND	0.007	MG/L
719900702-S	07/18/17	11/10/17	DIQUAT	EP-A	ND	0.02	MG/L
719900702-S	07/18/17	11/10/17	ENDOTHALL	EP-A	ND	0.1	MG/L
719900702-S	07/18/17	11/10/17	ENDRIN	EP-A	ND	0.002	MG/L
719900702-V	07/18/17	12/14/17	ETHYLBENZENE	EP-A	ND	0.7	MG/L
719900702-S	07/18/17	11/10/17	ETHYLENE DIBROMIDE	EP-A	ND	0.00005	MG/L
719900702-S	07/18/17	11/10/17	GLYPHOSATE	EP-A	ND	0.7	MG/L
719900702-R	07/18/17	11/10/17	GROSS ALPHA, EXCL. RADON & U	EP-A	5.3	15	PCI/L
719900702-S	07/18/17	11/10/17	HEPTACHLOR	EP-A	ND	0.0004	MG/L
719900702-S	07/18/17	11/10/17	HEPTACHLOR EPOXIDE	EP-A	ND	0.0002	MG/L
719900702-S	07/18/17	11/10/17	HEXACHLOROBENZENE	EP-A	ND	0.001	MG/L
719900702-S	07/18/17	11/10/17	HEXACHLOROCYCLOPENTADIENE	EP-A	ND	0.05	MG/L
719900702-S	07/18/17	11/10/17	LASSO	EP-A	ND	0.002	MG/L
719900702-S	07/18/17	11/10/17	METHOXYCHLOR	EP-A	ND	0.04	MG/L
719900702-V	07/18/17	12/14/17	O-DICHLOROBENZENE	EP-A	ND	0.6	MG/L
719900702-S	07/18/17	11/10/17	OXAMYL	EP-A	ND	0.2	MG/L
719900702-V	07/18/17	12/14/17	P-DICHLOROBENZENE	EP-A	ND	0.075	MG/L
719900702-S	07/18/17	11/10/17	PENTACHLOROPHENOL	EP-A	ND	0.001	MG/L
719900702-S	07/18/17	11/10/17	PICLORAM	EP-A	ND	0.5	MG/L

719900702-S	07/18/17	11/10/17	SIMAZINE		EP-A	ND	0.004	MG/L
719900702-V	07/18/17	12/14/17	STYRENE		EP-A	ND	0.1	MG/L
719900702-V	07/18/17	12/14/17	TETRACHLOROETHYLENE		EP-A	ND	0.005	MG/L
719900702-V	07/18/17	12/14/17	TOLUENE		EP-A	ND	1	MG/L
719900701-D	07/18/17	08/07/17	TOTAL HALOACETIC ACIDS (HAA5)		DIST-A	ND	0.06	MG/L
719900702-S	07/18/17	11/10/17	TOTAL POLYCHLORINATED BIPHENYLS -PCB		EP-A	ND	0.0005	MG/L
719900702-S	07/18/17	11/10/17	TOXAPHENE		EP-A	ND	0.003	MG/L
719900702-V	07/18/17	12/14/17	TRANS-1,2-DICHLOROETHYLENE		EP-A	ND	0.1	MG/L
719900702-V	07/18/17	12/14/17	TRICHLOROETHYLENE		EP-A	ND	0.005	MG/L
719900701-D	07/18/17	08/07/17	TTHM		DIST-A	ND	0.08	MG/L
719900702-V	07/18/17	12/14/17	VINYL CHLORIDE		EP-A	ND	0.002	MG/L
719900702-V	07/18/17	12/14/17	XYLENES, TOTAL		EP-A	ND	10	MG/L

717301001	06/21/17	07/14/17	COPPER	residence #1	DIST-A	0.065	1.3	MG/L
717301001	06/21/17	07/14/17	LEAD	residence #1	DIST-A	ND	0.015	MG/L
717301002	06/22/17	07/14/17	COPPER	residence #2	DIST-A	0.558	1.3	MG/L
717301002	06/22/17	07/14/17	LEAD	residence #2	DIST-A	0.008	0.015	MG/L
717301003	06/22/17	07/14/17	COPPER	residence #3	DIST-A	ND	1.3	MG/L
717301003	06/22/17	07/14/17	LEAD	residence #3	DIST-A	0.013	0.015	MG/L
717301004	06/21/17	07/14/17	COPPER	residence #4	DIST-A	ND	1.3	MG/L
717301004	06/21/17	07/14/17	LEAD	residence #4	DIST-A	0.003	c	MG/L
717301005	06/22/17	07/14/17	COPPER	residence #5	DIST-A	0.096	1.3	MG/L
717301005	06/22/17	07/14/17	LEAD	residence #5	DIST-A	0.002	0.015	MG/L
717301006	06/22/17	07/14/17	COPPER	residence #6	DIST-A	ND	1.3	MG/L
717301006	06/22/17	07/14/17	LEAD	residence #6	DIST-A	ND	0.015	MG/L
717301007	06/21/17	07/14/17	COPPER	residence #7	DIST-A	ND	1.3	MG/L
717301007	06/21/17	07/14/17	LEAD	residence #7	DIST-A	ND	0.015	MG/L
418903201-I	07/08/14	08/13/14	ARSENIC - EP FOR WELLS (9-yr cycle)		EP-A	ND	0.01	MG/L